

GOVT. OF WEST BENGAL OFFICE OF THE DIRECTOR GENERAL WEST BENGAL FIRE & EMERGENCY SERVICES 13-D, Mirza Galib Street, Kolkata - 700 016.

Memo. No.: WBFES/ 6836

Date: 13 01/11

From

Additional Director General,

West Bengal Fire & Emergency Services.

To

The Joint Secretary to the Govt. of West Bengal, School Education Department, Writer's Buildings,

Kolkata- 700 001.

and drawn

Sub.: Guldelines on Safety Measures for cooking Mid-day Meal

Ref.: Our Memo. No. WBJES/6293 dated- 23.12.2010.

In light of the discussion held in a meeting with the Principal Secretary, Department of Fire & Emergency Services and the Secretary, School Education Department, partial modification on the guidelines issued vide memo, no, under reference on safety measures for the schools operating Mid-day Meal Solieme has been made and reproduced hereunder.

- 1. Kitchens should be located at the ground floor level and detached from the main school building within the school premises. The construction can be made using flat RCC roof, CGI roofing, or with stone states spanned across pre-cast RC joists/metal sections. In case of space constrain the room be at the extreme end of the ground floor level and isolated from the other part of the building should be identified for the kitchen purpose. In respect of the individual school having small kitchens for supplying of mid-day meals to the students, the measurement of total built-up area of the kitchen may be within 8.41 Sq. Mtrs. The other parameters for kitchen cum store should follow the guidelines prescribed under National Program of Nutritional Support to Primary Education 2006 (Mid-Day Meal Scheme), published by School Education Department, Govt. of West Bengal.
- Gas oven shall be placed in raised platform. The platform should be at least 30 inches above the ground level to place the gas oven.
 - The individual school supplying cooked mid-day meal for their students, maximum 4 Nos. of L.P.G. eylinders Can be used without the provision of separate gas banks. The unused cylinders are to be kept in a separate place away from the oven and their seals are to be opened only at the time of replacement of only one cylinder at a time. The ovens and the cylinders are to be kept away from the main staircase so that even in case of fire there is no problem of egress and ingress of students from the upper floors.

- In respect of individual schools supplying Midaday Meal, applications for N.O.C. need not b. submitted to the Fire & Emergency Services Department. All individual schools are to follow this safety guidelines and are duly certified by the officials of the DI/Primary School
- 5. The distribution of food should be done through counters to avoid accessibility of students inside the kitchen
- 6. The kitchen should be protected by adequate number of Dry Chemical Powder type of fire extinguishers.
- The above guidelines should be implemented strictly by the school authority, those having individual Mid-day Meal Scheme.
- 8. The teaching and non-teaching staffs of the school and the workers for Mid-day Meal Scheme should have the adequate knowledge for operating fire extinguishers.
- 9. The authorities who are responsible for running a community kitchen for Mid-day Meal Scheme have to obtain N.O.C. from the Fire Service department.

Additional Director General. West Bengal Fire & Emergency Services Date :

Memo. No. : WBFES

Copy forwarded for information and necessary action to-

可力制制的确定 MARCHAEL

国 。自婚婚时,

1. The Principal Secretary to Govt. of West Bengal, Department of Fire & Emergency Services, Writers' Buildings, Kolkata-700 001.

2. The P.S. to Holl lie M.I.C., Department Fire & Emergency Services, Govt. of West Bengal, Writer's Buildings, Kolkata-700 001.

3. The Joint Municipal Commissioner, Kolkata Municipal Corporation, 5,

S.N. Banerjee Road, Kolkata.

Additional Director General West Bengal Fire & Emergency Services. .