



Government of West Bengal
Department of Health & Family Welfare
Swasthya Bhawan
GN-29, Sector-V, Salt Lake, Kolkata – 700 091

No. 215/HF/O/HS(MS)/W-17/2022

Date : 27/12/2022

NOTIFICATION

The Government of West Bengal has given thrust on smooth and hassle-free patient care services. To fulfil this objective, top most priority is to be accorded towards safety and security of all patients and staff as well as protection of hospital equipments from fire hazards. Several precautionary measures have already been taken to ensure proper fire safety mechanism in government health facilities. In view of this, a dedicated 'Committee on Fire Safety' for the municipal areas of Kolkata and at district level are already in place vide Notification No. HFW/294/2020 dt 29.12.2020.

Now it is further felt to constitute "Hospital Level Fire Safety Committee" at each health facility down to the level of Sub-Divisional Hospitals for close monitoring of the functionality of the fire safety measures and for checking up the health of all probable sources vulnerable from the point of catching fire. The "Hospital Level Fire Safety Committee" will consist of one representative from H&FW Deptt., one engineer each from Civil & Electrical Wing of PWD and one representative from Fire & Emergency Services Deptt..


This committee shall meet every fortnight; jointly inspect all the electrical installations, AC machines, equipments to assess their fire safety worthiness as per protocol. The committee will invariably check the following :-

1. DB Box and log of temperature
2. Earthing at all critical units along with voltage
3. Fire Alarm, Fire Sensor & Sprinkler
4. Availability & validity of Fire extinguishers
5. Evacuation route & plan
6. Provision of timer for Air Conditioning Machines of the hospital.
7. Provision of fire extinguishers in important areas of hospital like Emergency, Labour room OT, HDU, CCU, ITU, ICCU, NICU, PICU, SNCU, SNSU, etc.
8. Adequate Air Conditioning Machines with timer in Radiology units like C.T. Scan units, Digital X Ray units, which run for 24x7 hours
9. Functionality of public address system



The committee wherever finds any need-based actions, they should take immediate remedial steps and for any bigger issue that must be brought to the kind notice of higher authorities.

List of hospital level nodal officers from each of the H&FW, PWD and F&ES Departments will be circulated separately. All concerned are requested to activate the "Hospital Level Fire Safety Committee" soon and ensure their regular inspection and appropriate actions for the fire safety of the hospital.

 : 27/12/2022


Secretary
Health & Family Welfare Department
Government of West Bengal

No. 215/1(3)HF/O/HS(MS)/W-17/2022

Date : 27/12/2022

Copy for information to :

1. Additional Chief Secretary, Fire and Emergency Services Department
2. Secretary, Public Works Department
3. Director General of Fire Services, West Bengal

 : 27/12/2022


Secretary
Health & Family Welfare Department
Government of West Bengal

No. 215/2(9)HF/O/HS(MS)/W-17/2022

Date : 27/12/2022

Copy forwarded for kind information and necessary action to :

1. Director of Medical Education, West Bengal
2. Director of Health Services, West Bengal
3. Special Secretary, MERT Branch, H&FW Department
4. Principal/MSVP - All Medical College & Hospitals
5. Additional Director of Medical Education, H&FW Department
6. Deputy Director of Health Services, Hospital Administration Branch
7. Chief Medical Officer of Health - All districts and health districts
8. IT cell for Web posting
9. Office Copy

 : 27/12/2022

Additional Secretary
MS Branch
Health & Family Welfare Department
Government of West Bengal



Government of West Bengal
Department of Health & Family Welfare
Swasthya Bhawan
GN-29, Sector-V, Salt Lake, Kolkata-700091

Memo No. 216/HF/O/HS(MS)/W-17/2022

Date : 27.12.2022

From: Senior Special Secretary
Health & Family Welfare Department
Government of West Bengal

To: 1) Principal/MSVP - All Medical College & Hospitals
2) Chief Medical Officer of Health - All districts and health districts

Sub : Hospital Level Fire Safety Committee -- list of nodal officers

Ref : Notification no. 216/HF/O/HS(MS)/W-17/2022 dt.22.12.2022

Sir / Madam,

This is to bring to your kind notice that in pursuance of the Notification No. 216/HF/O/HS(MS)/W-17/2022 dt.22.12.2022, "**Hospital Level Fire Safety Committee**" at each health facility up to the level of Sub-Divisional Hospitals, is to be constituted with following members :-

1. One representative from H&FW Deptt.
2. One engineer each from Civil & Electrical Wing of PWD
3. One representative from Fire & Emergency Services Deptt

This committee will meet fortnightly for joint inspection and take all necessary steps for fire safety as mandated in the aforesaid notification.

The list of hospital wise nodal officers, who will be the members of the Fire safety Committee of the hospital, is annexed herewith for ready reference [**Annexure-I**]. All the names, mentioned in the list, have been recommended by the departments concerned. In case of any change in the positions due to transfer or any other reason, that should be informed to the Hospital Administration branch [**wbhabr.report@gmail.com**] for necessary modification in future.

During inspection, points mentioned in the check list [**Annexure-II**] must be thoroughly taken care of.

I would like to request you to kindly activate the facility wise teams immediately so that they start functioning from 1st week of January, 2023 without fail.

Yours sincerely,

Senior Special Secretary
Health & Family Welfare Department


Encl. – As stated

Memo No. 216/1(3)/HF/O/HS(MS)/W-17/2022

Date : 27.12.2022

Copy for kind information to :

1. Additional Chief Secretary, Fire and Emergency Services Department
2. Secretary, Public Works Department
3. Director General of Fire Services, West Bengal

 27/12/2022

Senior Special Secretary

Health & Family Welfare Department

Memo No. 216/2(7)/HF/O/HS(MS)/W-17/2022

Date : 27.12.2022

Copy forwarded for kind information and necessary action to :

1. Director of Medical Education, West Bengal
2. Director of Health Services, West Bengal
3. Special Secretary, MERT Branch, H&FW Department
4. Additional Director of Medical Education, H&FW Department
5. Deputy Director of Health Services, Hospital Administration Branch
6. IT cell for Web posting
7. Office Copy

 27/12/2022

Additional Secretary

HS (MS) Branch

Health & Family Welfare Department

LIST OF FACILITY WISE NODAL OFFICERS OF FIRE SAFETY

Sl No	NAME OF DISTRICT	CATEGORY OF HOSPITAL	NAME OF THE FACILITY	Nodal Officer of the Hospital (H& FW)	Nodal Officer of PWD (Electrical)	Nodal Officer of PWD (Civil)	Nodal Officer of F&ESD
1	24 Paraganas North	MCH	Barasat Govt. Medical College & Hospital	Mr.Akash Majumder, Assistant Superintendent, Mob. 8918561682	Partha halder-9073363060	Subrata Shyamal, AE, 9679270011	
2	24 Paraganas North	MCH	College of Medicine & Sagore Dutta Hospital MCH	JAHID HASAN, Assistant Superintendent 9382400871	Partha halder-9073363060	Sri Bimal Pal Executive Engineer-I, Kolkata North Health Divn. Phone No :- 8240197031 (For TCCC and Nursing Part only)	
3	24 Paraganas South	MCH	Diamond Harbour Government Medical College & Hospital	Rudranil Guchhait, Assistant Superintendent, 9007587230	Nirmalya Das-94333-01925 /9073363040	Sibendra Prasad Baidya. Assistant Engineer, Diamond Harbour Sub-Division, P.W.D. Mob No-7003480520, 9831175911	
4	Bankura	MCH	Bankura Sanmiloni MCH	Sudipto Kundu , DY. Supdt(NM),9830107856	Sirshendu Pal-6292121998	Dinobandhu Chatterjee, JE 9733110339	Abhay Chowdhary, Stn/Officer, Mo. No.9475652684
5	Birbhum	MCH	Rampurhat DH ,SSH & MCH	SUSMIT BHATTACHARYA, Assistant Superintendent,9433135610	Soumitra kumar Mallick-91430-63592/6292121995	Rajkumar Banthia, Assistant Engineer, PWD, Bolpur Construction Sub-Division. Mob. No.-8250641533	Md Ali
6	Coochbehar	MCH	MJN MCH	Dibyendu Das, Assistant Superintedent, Mob. No. 9733196969	Kaushik Deb-6292122008	Sri Subrata Sarkar, Assistant Engineer,PWD, 9832082157	SO Ranjan Modak Mob: 9474433523
7	Darjeeling	MCH	North Bengal Medical College and Hospital	Deb Kumar Pradhan, Assistant Superintendent 9008043067	kausik sahu-6292122005/98741-15149	Kinkar Bhowal, Executive Engineer, 9434257733	SO MANOJ KR THAKUR Mob: 8918821637
8	Dinajpur Uttar	MCH	Raiganj DH ,SSH & MCH	Abhik Maity, Assistant Superintendent, 8013732242	Biswanath mallick-6062122004/9476466743	Manok Hembram, Assistant Engineer, PWD, Raiganj Sub-Division No. - II, Ph.No. - 9903137837	Sudipta Mukherjee, Station Officer _ 9475474754
9	Hooghly	MCH	P C SEN (Arambagh) GOVT. MCH	Debotosh Das Assistant Superintendent (NM) 7908227609	Debaprasad samanta-9073363080/94334-64530	A. E. Anirban De Sub-divn, II [Mobile] +917908092190	Sabyasachi Chatterjee, Station Officer, 9474011371

SI No	NAME OF DISTRICT	CATEGORY OF HOSPITAL	NAME OF THE FACILITY	Nodal Officer of the Hospital (H& FW)	Nodal Officer of PWD (Electrical)	Nodal Officer of PWD (Civil)	Nodal Officer of F&ESD
10	Howrah	MCH	SARAT CHANDRA CHATTOPADHYAY GOVT. MCH	Mr.Nilanjan Pramanik , Assistant Superintendent Contact no -9679267246	Apurba das-9073362870	NA	Bhabani Prasad Dubey Mobile No. 9163983913
11	Jalpaiguri	MCH	Jalpaiguri MCH	Moloy Kanti Dey, Assistant Superintendent, 9038867961 Susnata Roy, Assistant Superintendent,9874702069	Sumanta chakraborty-6292122006/96746-99457	Saibal Das, EE, 9874960653	SO Rameswar Pandey Mob: 8101616919
12	Jhargram	MCH	Jhargram MCH	Dr. Indranil Sarkar, Additional Medical Superintendent, Mob. 8250995321	Amallesh Biswas-6292122000/	Rabindra Nath Dey, Executive Engineer,PWD 8936490857	JADUNATH HEMBRAM, O/C Jhargram F/S. M.No.- 9732850627
13	Kolkata	MCH	RG Kar Medical College	SURAJIT SEN, Dy.Superintendent (NM) 8777391220 AND ANITA DHARA Assistant Superintendent (NM) Grade II 9831298845	Bansharilal Mondal-94756-87148/9073361888	Bimal Pal Executive Engineer-I, Kolkata North Health Divn. Phone No :- 8240197031	
14	Kolkata	MCH	Dr B.C Roy Post Graduate Institute of Pediatric sciences Kolkata MCH	MD. ALAMGIR RAHMAN,Assistant Superintendent (9609196526)	Bansharilal Mondal-94756-87148/9073361888	Bimal Pal Executive Engineer-I, Kolkata North Health Divn. Phone No :- 8240197031	
15	Kolkata	MCH	Kolkata Medical Collage & Hospital	Sanghamitra Bannerjee, Assistant Superintendent , 9903033995	Amlan Bhattacharaya-94777-36743	Partha Roy Executive Engineer-II, Kolkata North Health Divn. Phone No :- 9830070608	
16	Kolkata	MCH	School of Tropical Medicine MCH	Smt. Sangita Sil, Assistant Superintendent9830290994	Bansharilal Mondal-94756-87148/9073361888	Partha Roy Executive Engineer-II, Kolkata North Health Divn. Phone No :- 9830070608	
17	Kolkata	MCH	NRS Medical Collage & Hospital	Ajanta Pal,Assistant Superintendent (9874916454)	Arindom Halder-9593900995/94340-43324	Sk. Hasanuj Jaman Executive Engineer-I, Kolkata Central Health Divn. Phone No :-9073362370	SUMIT SUR 9433499046
18	Kolkata	MCH	Calcutta National Medical Collage & Hospital	Mr. Ardherndu Dinda , DSNM (for hospital side), 7003429818	Tarit Pal-94339-64537 / 89813-36561	Bidyut Maiti Executive Engineer-II, Kolkata Central Health Divn. Phone No :-9733635650	SUMIT SUR 9433499046
19	Kolkata	MCH	Chitaranjan Seva Sadan MCH	Arunima Chakraborty ,Dy. Supdt.(N/M) ,9477645241	Asif Ikbal-85840-41971 /97493-01242	Sri Kaushik Kumar Executive Engineer & T.A. to S E Phone No :- 9433238780	SHUBHAJIT SAHA 9804151436
20	Kolkata	MCH	SSKM Medical College & Hospital	Subhajit Roy , Assistant Superintendent (N.M) Mob - 7980765381) & Dr. Biswajit Mandal , Addl..Medical Superintendent - III , Mob - 9331025452)	Maznu Dhali-9163182919	Nilanjan Saha Executive Engineer-I, Kolkata South Health Divn. Phone No :-9733635650	SUMIT SUR 9433499046
21	Maldah	MCH	Maldah DH & MCH	Ananya Dhar, Deputy Superintendent (N/M),Phn-9832059038	Pranab Mondal-6292122003	Asit Kr Saha, EE, 9433321460	Ratan kr: Singh,Station Officer Ph . No. 9851038655

SI No	NAME OF DISTRICT	CATEGORY OF HOSPITAL	NAME OF THE FACILITY	Nodal Officer of the Hospital (H&FW)	Nodal Officer of PWD (Electrical)	Nodal Officer of PWD (Civil)	Nodal Officer of F&ESD
22	Medinipur East	MCH	Tamluk MCH	Dr. Tapan Kumar Maity, Dy. Supdt. 9883244401	Goutam Ghosh-94341-97790/6292122002	RABINDRA NATH SAMANTA, Assistant Engineer, Tamluk Sub Division, 9434517383	Ashim Kumar Ghosh, O/C Tamluk Fire Station. M.No. 9874726820
23	Medinipur West	MCH	Medinipur DH & MCH	S Chakraborty, Assistant Superintendent 9735344377	Rajesh naskar-6292122001/78906-18118	Goutam Das Assistant Engineer Mldnapur Sub-Division 9836080082	Gopal Chandra Ghosh, O/C Medinipur F/S. M.No.-8017421973.
24	Murshidabad	MCH	Murshidabad Medical College Hospital & DH	SOMEN SAHA, Assistant Superintendent 9474579911	Soumya Maiti - 9330063960	Sujay Sarkar, EE, 9434435116	
25	Nadia	MCH	College of Medicine & Jawaharlal Nehru Memorial Hospital Kalyani MCH	Kasturi Basu Chakraborty ,Assistant Superintendent 8479904922	Debasis pal-6292121993/9830673524	Aurobinda Dey,EE 7001871180	
26	Purba Bardhaman	MCH	Barddhaman MCH	MR.WASIM ALAM, Assistant Superintendent 8927688350	Joydip chakraborty-6292121996/9433234499	Indranil Mukherjee, Assistant Engineer, 9874874368	Sanjay Dutta, Station Officer, 8617595503
27	Purulia	MCH	D.M.Sadar DH, SSH & MCH	Ankita Kole ,Assistant Superintendent, (8327693223)	Adwaita majhee-94344-73553 7001499136	Souvik Manna, Asisitant Engineer, Purulia Sub-Division, PWD MB No. 6292122179	Nimai Ch. Mandal, Officer-In-Charge, Purulia Fire Station, 9851290245
28	Alipurduar	DH	Alipurduar District Hospital	Priyam Deb (9874823367), Facility Consultant Quality Monitoring	Kaushik Deb-6292122008	Durlav Mondal, AE, 9932700124	
29	Basirhat HD	DH	Basirhat District Hospital	Tanusree Chatterjee, Assistant Superintendent, 9051378915	Partha halder-9073363060	Tausif Islam, AE, 70010283384	
30	Birbhum	DH	Suri District Hospital	Joydev Nayek ,Assistant Superintendent,	Soumitra kumar Mallick-6292121995/91430-	Joydev Nayak, AE, 8373070874	Md Ali
31	Bishnupur HD	DH	Bishnupur District Hospital	SUDEEP KR.PAL-Assistant Superintendent, 9614455900	Sirshendu Pal-6292121998/99331-64743	Dipankar jana, EE, 8436779140	Sanat Karmakar, Stn/Officer, Mo.No. 8967303876
32	Dakshin Dinajpur	DH	Balurghat District Hospital	AYYAN SINHA, Assistant Superintendent, 8240929758	Biswanath mallick-6062122004/9476466743	SOUVIK SAHA ASSISTANT ENGINEER BALULRGHAT SUB DIVISION NO.II PWD 6292122304	Madan Kumar De, Station Officer-7076707445, Binoy Barman, Station Officer - 9832309954, Santanu Majumder, Station Officer - 8918219787
33	Darjeeling	DH	Darjeeling (Eden) District Hospital	Amiya kumar Mandal, Assistant Superintendent ph number-9434494401	kausik sahu-6292122005/98741-15149	NA	SO Suresh Kumar Tamang Mob: 9563079440

SI No	NAME OF DISTRICT	CATEGORY OF HOSPITAL	NAME OF THE FACILITY	Nodal Officer of the Hospital (H&FW)	Nodal Officer of PWD (Electrical)	Nodal Officer of PWD (Civil)	Nodal Officer of F&ESD
34	Darjeeling	DH	Siliguri District Hospital	MS TANUSHREE DAS, Dy. Superintendent (NM), 9433571212	kausik sahu-6292122005/98741-15149	Tanmoy Sarkar, AE +91 94343 91152	SO Bhaskar Nag Mob: 9434151885
35	Hooghly	DH	Chinsurah District Hospital	KAMALIKA RAY, Dy. Superintendent (NM),9051304155	Debaprasad samanta-9073363080/94334-64530	Jogannath Dey Assistant Engineer PWD, Hooghly Sub Division-I 9073362617	Debasish Biswas, Station Officer, 9932003037
36	Howrah	DH	Howrah District Hospital	RIA BASU,ASSISTANT SUPERINTENDENT, 9874323572	Apurba das-9073362870	Asit Chandra Bindra, AE 9073360606	Ramkrishna Saha Mobile no. 7980484102, 9051775156
37	Kalimpong	DH	Kalimpong District Hospital	DR. Anowar Hossain , Superintendent, (94347 56065)	kesang lhamu bhutia-9474076434	Rajib Sarkar,EE,9733090858	SO Bharat Lama Sherpa Mob: 8918965097
38	Nadia	DH	Krishnanagar District Hospital	Golak Mondal , Assistant Superintendent,7548975211	Debasis pal-6292121993/9830673524	Aurobindo Dey, EE	
39	Nandigram HD	DH	Nandigram District Hospital	RATNA TUNG MONDAL ,Assistant Superintendent, 7362989987	Goutam Ghosh-94341-97790/6292122002	NA	Tarakesh Ranjan Sinha, Station Officer, 9674190726
40	Paschim Bardhaman	DH	Asansol District Hospital	Bhaskar Hazra,Assistant Superintendent, Ph-9732094712	Nayan Garai-6292121997/	Rupesh Barui, Executive Engineer 94741 43891	Debayan Podder,Station OFFICER,9851266709
41	South 24 Parganas	DH	MR Bangur District Hospital	SAGAR CHANDRA SIT, Dy. Superindent (NM),8617344125	Asif Ikbal-85840-41971 /97493-01242	Kaushik Kumar Executive Engineer & T.A. to S.E Phone No :- 9433238780	

Sl No	NAME OF DISTRICT	CATEGORY OF HOSPITAL	NAME OF THE FACILITY	Nodal Officer of the Hospital (H&FW)	Nodal Officer of PWD (Electrical)	Nodal Officer of PWD (Civil)	Nodal Officer of F&ESD
1	Bankura	SDH	Khatra Sub Division Hospital	Dr. Ratan Kumar Sasmal, Superintendent, 9547824472	Shirshendu Paul- 6297446722	Sudip Sahana, Executive Engineer 9434144442	
2	Birbhum	SDH	Bolpur Sub Division Hospital	Sirajuddolla Sekh, Asstt. Superintendent, Mob: 9265370533	Soumitra kumar Mallick- 6292121995/91430-63592	Rajkumar Banthia, Assistant Engineer, PWD, Bolpur Construction Sub-Division, Mob. No.-8250641533	
3	Coochbehar	SDH	Dinhata Sub Division Hospital	DR. RANJIT MANDAL, Superintendent, 9434542822	Kaushik Deb-6292122008	Sri Prabir Kr Saha, Assistant Engineer, PWD, 8918811997	SO Gobinda Barman Mob: 8906564778
4	Coochbehar	SDH	Mathabhanga Sub Division Hospital	Abhishek Kanjilal, Assistant Superintend 9641363961	Kaushik Deb-6292122008	Sri Subodh Karmakar, Assistant Engineer, PWD, 9434878151	SO Narendra Nath Roy Mob: 9749062026
5	Coochbehar	SDH	Mekhliganj Sub Division Hospital	Dr.Tapas Kumar Das, Superintendent, (9474960946)	Kaushik Deb-6292122008	Samad Ali, AE 9647025459	SO Gabinda Roy Mob: 9476274669
6	Coochbehar	SDH	Tufanganj Sub Division Hospital	Kishor Barman, Asst. Supdt. Mob. 7908598622/ Suhash Ranjan Chakraborty. Asst. Super Mob. 9851769019	Kaushik Deb-6292122008	Sri Subrata Sarkar, Assistant Engineer, PWD, 9832082157	SO Binay Sarkar Mob: 9434083927
7	Dakshin Dinajpur	SDH	Gangarampur Sub Division Hospital	Tushar Ranjan Das, Dy.Supdt(NM) 9547452442	Biswanath mallick- 6062122004/9476466743	BISHAL CHATTERJEE ASSISTANT ENGINEER GANGARAMPUR SUB DIVISION PWD 6292122305	
8	Darjeeling GTA	SDH	Kurseong Sub Division Hospital	SHRI KRISHNA GHOSH , Assistant Superintendent, 9832522293	kausik sahu-6292122005/98741-15149	GTA	SO Bhakta Bahadur Godaily Mob: 9563270312
9	Diamond Harbour	SDH	Kakdwip Sub Division Hospital	Mrs. Arpita Mistry (Asst. Superintendent), 9932905836	Nirmalya Das-94333-01925 /9073363040	Raja Chatterjee-09674068370	
10	Hooghly	SDH	Chandannagar Sub Division Hospital	Priyanka Porel ,Assistant Superintendent, 9547947960	Debaprasad samanta- 9073363080/94334-64530	Tapas Mukhapadhayay Assistant Engineer PWD Hooghly Sub Division-II 9073362619	Kripasindhu Dey, Station Officer, 9903165814
11	Hooghly	SDH	Walsh Srerampur Sub Division Hospital	Durba Banerjee, Dy. Super, M- 9830116902	Debaprasad samanta- 9073363080/94334-64530	Utpal Maity Assistant Engineer PWD Serampore Sub Division 9477220965	Sabyasachi Chatterjee, Station Officer, 9474011371
12	Jalpaiguri	SDH	Mal Sub Division Hospital	Dipankar Sarkar ,Assistant Superintendent(Mob- 9433905647)	Sumanta chakraborty- 6292122006/96746-99457	Saibal Das, EE, 9874960653	SO Bichitra Tarafdar Mob: 9641960209
13	Maldah	SDH	Chanchal Sub Division Hospital	Sri Santanu Karmakar, Assistant Superintendent, 9883700392	Pranab Mondal-6292122003	Asit Kr Saha, EE, 9433321460	
14	Murshidabad	SDH	Domkol Sub Division Hospital	MR.MEHBUB ZAHEDI ,Assistant Superintendent, Phone No: 7548941186	Soumya Maiti -9330063960	Ranjan Mukherjee, Assistant Engineer, 9475418898	
15	Murshidabad	SDH	Jangipur Sub Division Hospital	Prosanto Kr.Mondal, Assistant Superintendent, 7980354467	Soumya Maiti -9330063960	Biplab Chanda, Assistant Engineer, 9474442276	
16	Murshidabad	SDH	Kandi Sub Division Hospital	Soumendu Kumar Sinha ,Assistant Superintendent, 7908336379	Soumya Maiti -9330063960	Gopal Narayan Ray, Assistant Engineer, 9475156675	
17	Murshidabad	SDH	Lalbagh Sub Division Hospital	Dr. MD. MEHFUZ MANDI, SUPERINTENDENT, 7278780492	Soumya Maiti -9330063960	Sohan Sukul, Assistant Engineer, 6292122115	

SI No	NAME OF DISTRICT	CATEGORY OF HOSPITAL	NAME OF THE FACILITY	Nodal Officer of the Hospital (H&FW)	Nodal Officer of PWD (Electrical)	Nodal Officer of PWD (Civil)	Nodal Officer of F&ESD
18	Nadia	SDH	Ranaghat Sub Division Hospital	Taposh Paul, Assistant Superintendent, 7699465998	Debasis pal-6292121993/9830673524	Aurobinda Dey, EE 7001871180	
19	Nadia	SDH	Tehetta Sub Division Hospital	S.M. Azad, Assistant Superintendent 7548975290	Debasis pal-6292121993/9830673524	Aurobinda Dey, EE 7001871180	
20	Nandigram Health District	SDH	Contai Sub Division Hospital	Sk. Moidul Rahaman, Assistant Superintendent, 9734316437	Goutam Ghosh-94341-97790/6292122002	MD KAMRUZZAMAN, Assistant Engineer, Contai Sub Division, 6292122195	MONOTOSH SAHOO, O/C Contai f/S. M.No.- 7872757847
21	North 24 Parganas	SDH	BN Bose Sub Division Hospital	Priyadeep Mukherjee, Dy. Superintendent (NM), (9674455414),	Partha halder-9073363060	Raghunath Mohanto Mob: 8100022305	
22	North 24 Parganas	SDH	Bongaon Sub Division Hospital	Debolina Chakraborty, Assistant Superintendent, Phone no:- 9163369030	Partha halder-9073363060	Bankim Majumder, Assistant Engineer, 8910200052	
23	North 24 Parganas	SDH	Saltlake Sub Division Hospital	Alolika Mallick, Assistant Superintendent, 8820202080	Partha halder-9073363060	Bimal Pal Executive Engineer-I, Kolkata North Health Divn. Phone No :- 8240197031	
24	Paschim Barddhaman	SDH	Durgapur Sub Division Hospital	Soumyadeep Mondal, Assistant Superintendent 8583804624	Nayan Garai-6292121997/	Rupesh Barui, Executive Engineer 94741 43891 Nalin Hasda, Assistant Engineer, 70030 71109	Debayan Podder, Station OFFICER, 9851266709
25	Paschim Medinipur	SDH	Ghatal Sub Division Hospital	Mr. Suvendu Bayen, Assistant Superintendent 7797248117	Rajesh naskar-6292122001/78906-18118	Atanu Maiti, EE, 6292121963	SWAPAN PATRA, O/C Ghatal Fire Station, M.No. - 9903495042.
26	Paschim Medinipur	SDH	Kharagpur Sub Division Hospital	Dr. Uttam Mandi, Superintendent, 6295169406	Rajesh naskar-6292122001/78906-18118	Atanu Maiti, EE, 6292121963	Nirmal Kumar Murmu, O/c Kharagpur fire station. M, No - 9775071911.
27	Purba Barddhaman	SDH	Kalna Sub Division Hospital	MR.SAMIM MALLICK, Assistant Superintendent, 9233688423	Joydip chakraborty-6292121996/9433234499	Ujjal Kumar Dutta, Assistant Engineer, Kalna Sub Division, 9434120098, 8116853711(M)	Arindam Debnath, Station Officer, 9732168456
28	Purba Barddhaman	SDH	Katwa Sub Division Hospital	Mr. Supriya Dutta, Assistant Superintendent, 9332308733	Joydip chakraborty-6292121996/9433234499	Ujjal Kumar Dutta, Assistant Engineer, Katwa Sub Division, 9434120098,	Arindam Debnath, Station Officer, 9732168456
29	Purba Medinipur	SDH	Egra Sub Division Hospital	Dr. Samir Acharya, Superintendent, 8648848649	Goutam Ghosh-94341-97790/6292122002	Atanu Maiti, EE, 6292121963	NEMAI BANARJEE, O/C Egra F/S. 9064787949.
30	Purba Medinipur	SDH	Haldia Sub Division Hospital	ARNAB KUMAR MUNIAN, Assistant Superintendent, 9647602933	Goutam Ghosh-94341-97790/6292122002	SUBHASIS PRAMANIK, Assistant Engineer, Haldia Construction Sub Division No.1, 6292122196	TARKESH RANJAN SINHA, O/C Haldia f/S. M.No.- 9674190726
31	Purulia	SDH	Raghunathpur Sub Division Hospital	Susmit Mukhopadhyay - Assistant Superintendent -Gr-II. Mb: 9474910885	Adwaita majhee-94344-73553 7001499136	Apurba Roy, Assistant Engineer, Raghunathpur Sub-Division, PWD, MB No 8967086339	JADU KRISHNA GHOSH, Officer In Charge, Raghunthpur Fire Station, 8145864041
32	South 24 Parganas	SDH	Baruipur Sub Division Hospital	MRINMOY DUARI, Assistant Superintendent, (8334806161)	Nirmalya Das-94333-01925 /9073363040	Arijit Pal, Junior Engineer Baruipur Sub Division Social Sector 9434154195	
33	South 24 Parganas	SDH	Canning Sub Division Hospital	MR. SUBHRAJIT GHOSH, Assistant Superintendent, 9748099852	Nirmalya Das-94333-01925 /9073363040	Sujit Kirtania AE Canning Sub Division Social Sector 9073362738	

Sl No	NAME OF DISTRICT	CATEGORY OF HOSPITAL	NAME OF THE FACILITY	Nodal Officer of the Hospital (H&FW)	Nodal Officer of PWD (Electrical)	Nodal Officer of PWD (Civil)	Nodal Officer of F&ESD
34	Uttar Dinajpur	SDH	Islampur Sub Division Hospital	RANAJIT BISWAS, Assistant Superintendent	Biswanath mallick-6062122004/9476466743	Somnath Bhattacharjee, Assistant Engineer, PWD, Islampur Sub-Division,	

SI No	NAME OF DISTRICT	CATEGORY OF HOSPITAL	NAME OF THE FACILITY	Nodal Officer of the Hospital (H& FW)	Nodal Officer of PWD (Electrical)	Nodal Officer of PWD (Civil)	Nodal Officer of F&ESD
1	Hooghly	SGH	Uttarpara State General Hospital	TANURIMA NUNDY,Dy. Superintendent (nm), 9830479882	Debaprasad samanta-9073363080/94334-64530	Utpal Maity Assistant Engineer PWD Serampore Sub Division 9477220965	Kripasindhu Dey, Station Officer, 9903165814
2	Howrah	SGH	Bauria Fort Gloster State General Hospital	Dr. Tapan Palit,Superintendent, 9804760549	Apurba das-9073362870	Timir Baran Saha, AE 98041 46566	Bhabani Prasad Dubey mobile No. 9163983913
3	Howrah	SGH	Belur State General Hospital	Dr. Santosh Thakur ,Superintendent, 9830731954	Apurba das-9073362870	Partha Sarathi Dutta, AE 79808 82003	Ramkrishna Saha Mobile no. 7980484102, 9051775156
4	Howrah	SGH	Gabberia State General Hospital	SOURINI BOSE ,Assistant Superintendent, 9123819525	Apurba das-9073362870	Timir Baran Saha, AE 98041 46566	Bhabani Prasad Dubey Mobile No. 9163983913
5	Howrah	SGH	South Howrah State General Hospital	Dr. Goutam Biswas, Superintendent, 9830894621	Apurba das-9073362870	Partha Sarathi Dutta, AE 79808 82003	Ramkrishna Saha Mobile no. 7980484102, 9051775156
6	Howrah	SGH	TL Jaiswal State General Hospital	DR.B.N.SAREN, Superintendent, M- 9073720133	Apurba das-9073362870	Timir Baran Saha, AE 98041 46566	Ramkrishna Saha Mobile no. 7980484102, 9051775156
7	Howrah	SGH	Udaynarayanpur State General Hospital	TANAY MUKHERJEE,Assistant Superintendent, 9830295388	Apurba das-9073362870	Timir Baran Saha, AE 98041 46566	Bhabani Prasad Dubey Mobile No. 9163983913
8	Nadia	SGH	Chakdah State General Hospital	PARAMITA BISWAS, Assistant Superintendent, 9953486583	Debasis pal- 6292121993/9830673524	Narayan Chandra Pal Executive Engineer, 7003996301	
9	Nadia	SGH	Nabadwip State General Hospital	SOMALI MONDAL, Assistant Superintendent, 8250178365	Debasis pal- 6292121993/9830673524	Aurobinda Dey,EE 7001871180	
10	Nadia	SGH	Santipur State General Hospital	Soma Das, Assistant Superintendent,9800860114	Debasis pal- 6292121993/9830673524	Narayan Chandra Pal Executive Engineer, 7003996301	
11	Nandigram Health District	SGH	Digha State General Hospital	Dr. Sandip Bagh, Superintendent, 8240166162	Goutam Ghosh-94341- 97790/6292122002	NA	DILIP KUMAR GUCHCHHAYET, O/C Ramnagar F/S. M.No.- 9647016798.
12	North 24 Parganas	SGH	Ashokenagar State General Hospital	Dr. Ramkrishna Hembram, Superintendent, 9883734167	Partha halder-9073363060	Ashim Kumar Debnath Executive Engineer, 6292121949	
13	North 24 Parganas	SGH	Baranagar State General Hospital	Dr. Paramita Maity, Superintendent,7605057322	Partha halder-9073363060	Smt Beauty Rani Biswas, AE,8906343368	
14	North 24 Parganas	SGH	Bhatpara State General Hospital	Abhishek Kumar,Assistant Superintendent,Mob-6290141553	Partha halder-9073363060	Tapan Kumar Ghosh. Mob: 7044276850	
15	North 24 Parganas	SGH	Habra State General Hospital	Abhishek Mukherjee,Assistant Superintendent 9674337693	Partha halder-9073363060	Ashim Kumar Debnath Executive Engineer, 6292121949	

SI No	NAME OF DISTRICT	CATEGORY OF HOSPITAL	NAME OF THE FACILITY	Nodal Officer of the Hospital (H&FW)	Nodal Officer of PWD (Electrical)	Nodal Officer of PWD (Civil)	Nodal Officer of F&ESD
16	North 24 Parganas	SGH	Naihati State General Hospital	Debashis Raha, Asst Supdt., Mob-9051052265	Partha halder-9073363060	NA	
17	North 24 Parganas	SGH	Panihati State General Hospital	Rahul Das, Asst. Superintendent 8001621097	Partha halder-9073363060	NA	
18	North 24 Parganas	SGH	Shree Balaram Seva Mandir State General Hospital	Smt Parna Gayen, Assistant Superintendent, 9123955366	Partha halder-9073363060	Raghunath Mohanta Mob: 8100022305	
19	Scuth 24 Parganas	SGH	Baghajatin State General Hospital	Chaitali Sen Gupta Asst. Super 9051475777	Partha halder-9073363060	Kaushik Kumar Executive Engineer & T.A. to S.E Phone No :- 9433238780	
20	Scuth 24 Parganas	SGH	Bijoygarh State General Hospital	Dr. Susmita Roy, Superintendent-98302269	Nirmalya Das-94333-01925 /9073363040	Kaushik Kumar Executive Engineer & T.A. to S.E Phone No :- 9433238780	
21	Scuth 24 Parganas	SGH	Garden Reach State General Hospital	TANIA AFTAR, ASSISTANT SUPERINTENDENT-9073719402	Nirmalya Das-94333-01925 /9073363040	Kaushik Kumar Executive Engineer & T.A. to S.E Phone No :- 9433238780	
22	Scuth 24 Parganas	SGH	Vidyasagar State General Hospital	MALLIKA DAS, Assistant Superintendent7003556464	Nirmalya Das-94333-01925 /9073363040	Kaushik Kumar Executive Engineer & T.A. to S.E Phone No :- 9433238780	
23	Alipurduar	SGH	Birpara State General Hospital	Bipul Bose, Assistant Superintent 9647817916	Kaushik Deb-9434367598	Pradip Halder- Executive Engineer 8670928712	
24	Uttar Dinajpur	SGH	Kaliyaganj State General Hospital	SANCHARI BHATTACHARJEE, Assistant Superintendent :8918929017	Biswanath mallick-6062122004/9476466743	BABUN HALDAR, Assistant Engineer, PWD, Raiganj Sub - Division No. I, Karnajora,	
25	Alipurduar	SSH	Falakata SSH	Krishnendu Biswas,Assistant Superintendent 8420507892	Kaushik Deb-6292122008	NA	SO Binay Kumar Barman Mob: 8972324850
26	Bankura	SSH	Barjora SSH	Towsif Ahamed Mallick,Assistant Superintendent (8509658547)	Sirshendu Pal-6292121998/99331-64743	NA	Sanat Karmakar, Stn/Officer, Mo.No. 8967303876
27	Bankura	SSH	Chhatna SSH	Mr. Manojit Das,Assistant Superintendent , 8961381751	Sirshendu Pal-6292121998/99331-64743	NA	Abhay Chowdhary, Stn/Officer, Mo. No.9475652684
28	Bankura	SSH	Onda SSH	Mr Sourav Das,Assistant Superintendent, 7908469068	Sirshendu Pal-6292121998/99331-64743	NA	Sanat Karmakar, Stn/Officer, Mo.No. 8967303876

SI No	NAME OF DISTRICT	CATEGORY OF HOSPITAL	NAME OF THE FACILITY	Nodal Officer of the Hospital (H&FW)	Nodal Officer of PWD (Electrical)	Nodal Officer of PWD (Civil)	Nodal Officer of F&ESD
29	Jhargram	SSH	Gopiballavpur SSH	Dr. Bidyut Patar, Superintendent, 8250995322	Amalesh Biswas-6292122000/	NA	JADUNATH HEMBRAM, O/C Jhargram F/S. M.No.- 9732850627
30	Jhargram	SSH	Nayagram SSH	Sushil kr.Murmu ,Assistant Superintendent 6294400768	Amalesh Biswas-6292122000/	NA	JADUNATH HEMBRAM, O/C Jhargram F/S. M.No.- 9732850627
31	Murshidabad	SSH	Sagardighi SSH	SABYASACHI DAS ,Assistant Superintendent PH NO-8918110366	Soumya Maiti -9330063960	NA	
32	Paschim Medinipur	SSH	Belda SSH	Dr. ASISH KUMAR MONDAL, SUPERINTENDENT , 9434341384	Nayan Garai-6292121997/	NA	Mujibar Rahaman, station Officer Kharagpur F/S. M.No.- 7872026757
33	Paschim Medinipur	SSH	Debra SSH	Anisur Rasul,Assistant Superintendent 7602397833	Nayan Garai-6292121997/	NA	Nirmal Kumar Murmu, O/c Kharagpur fire station. M,No - 9775071911.
34	Paschim Medinipur	SSH	Salboni SSH	Gita Murmu-Assistant Superintendent, 8670385671	Nayan Garai-6292121997/	NA	CHINMAY BOXI, Station Officer Medinipur F/S. M. No.- 7501121006
35	Paschim Medinipur	SSH	Panskura SSH	Chandan Mondal, Assistant Superintendent-7602031071	Nayan Garai-6292121997/	NA	KARTIK PATTANAYEK, station Officer, Tamluk F/s. M. No.- 9679709041

Annexure - II

Checklist (to be filled up by PWD ELEC)

Name of the Hospital:

Date and time of Inspection:

Name of the Building:

Floor:

1. Condition of Panel / sub-station Area/ Adjoining Area:

2. Electrical Installation and Distribution

I . The electrical installation including Transformers, Switch Gear, Main & Meters etc. and the distribution system of the premises is made satisfying the code of practice for Fire Safety in general building as laid down in I.S. specification 1946-1982.---Y/N

II. The vertical and horizontal electrical ducts is sealed at each floor level by fire resisting materials. Y/N

III. The electrical installation is adequately protected with CO2/D.C, P. Fire Extinguishers conforming I.S. specification. Y/N

IV. Arrangement for alternative power supply is made to supply power with the help of a generator to operate at least the Fire Pump, Deep Tube-Well Pump, Fire Alarm system etc. and also for illuminating the staircase, corridors, lobbies etc. and other places of assembly of the building in case of normal power failure. Available /Not Available

3. Condition of Fan & Light :

4. AIR CONDITIONING SYSTEM:

I. Condition of Air-conditioners:

II. The A.H.U. is separated for each floor with the system. Air Ducts are there for individual floors.

Y/N

III. Arrangement is made for isolation at the strategic locations by incorporating auto dampers in the Air Conditioning System. Y/N

IV. The system of auto shut down of A.H.U. is incorporated with the Auto Detection and Alarm System. Y/N

V. The Air Handling Unit room is used for storage of any combustible materials. Found satisfied. Y/N

5. Condition of Lift:

I. The walls of the Lift enclosure is at least two hours Fire Resisting type. Y/N

II. Collapsible gate shall not be permitted in front of the lift. Y/N

III. The lift is designed for Fire Lift as per guide line of N.B.C. part-IV. The word "FIRE LIFT" is conspicuously right at ground floor. Y/N

IV. If Lift and Lift Lobby is communicated to the basement and is pressurized as per guide line of N.B.C. part-IV, 2016. Y/N

6. Condition of Door closure and Window of the AIR Conditioning Machine:

7. Condition of OT/SNCU/ICCU/ICU/ITU/NICCU/PICU:

8. Testing of Insulation Resistance of the Panel & Earthing of the system (quarterly):

9. Condition of loose wire:

10. DETECTION AND ALARM SYSTEM:

1. Manually operated Electrical Fire Alarm System with at least three numbers of break glass type call boxes fitted with its Hooters along with Public Address System at each floor connecting with visual panel board is made in Control Room. The Control Room is located at entrance of ground floor of the building, other requirements of the system shall be made conforming I.S.2189-1988. Y/N
2. Auto Fire detection System with the help of Heat and Smoke Detectors is installed at all places of below and preferably above false ceiling of the building. The system is made in place of rooms where valuable articles have been kept. The other requirements of the system is made in accordance with I.S. 2189-1988. Y/N
3. The suppression system is made with Fire Extinguishers and total flooding system with CO2/F. M.-200 particularly in Computer. Electrical processing and Data Room are of irreplaceable articles. Y/N
4. Hooters are sounded in such a manner so that an operation of a Detectors or Manual Call Point. Hooters must be sounded on the same floor and immediate alternate floor. Y/N
5. Public Address System linked between all floors and Control Room is established. Y/N

11. INTELLIGENCE ANALOGUE SYSTEM:

- i. Auto Fire Alarm System with Analogue Addressable Smoke /Heat Detectors as per suitability is installed in each floor. Y/N
- ii. Addressable analogue manual call boxes incorporating with sounders is installed in all floors area of the building in such a manner that maximum travel distance is more than 22.5 mtrs. in order to reach any of the call point. Y/N
- iii. Micro Processor based Fire Alarm Panel is installed and all in connected with main panel at the Fire Control Room of the premises having direct dialing facility to the local Fire services unit. Y/N
- iv. Both way Public Address Systems shall be made available in all floors of the building. The system shall be connected to the main Control Room. Y/N
- v. All the installations shall also satisfy the I.S. specifications 2189 (as amended) and the code of practice as laid dozen in the N.B.C. PART - IV. Y/N

Checklist (to be filled up by Hospital Authority)

Name of the Hospital:

Date and time of Inspection :

Name of the Building :

Floor:

1. Fire License is obtained for proposed storing and processing with L.P.G. and other highly combustible articles. The L.P. G gas bank is provided for storing and processing with L.P.G.
Y/N
2. Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building
Y/N
3. Floor numbers and directional sign of escape route is displayed prominently. Y/N
4. The employees and security staffs is conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing. Y/N
5. Arrangements are there for regular checking, testing and proper maintenance of all the Fire Safety installation and proper maintenance of all Fire Safety Installation and equipments installed in the building to keep them in perfectly working conditions at all times. Y/N
6. A crew of trained Fireman under the experienced Fire Officer is maintained round the clock for safety of the building. Mock Fire practice and Evacuation drill is performed periodically with participation of all occupants of the building. Y/N
7. The corridors and staircase is free from any junk material: Y/N
8. The roof is clear, open to sky and devoid of any temporary structure and no refuse material dumping seen. Y/N
9. The Fire Check Doors/ Doors at the escape route are not locked : Y/N
10. Use of Electric Heater banned in the hospital except kitchen and canteen : Y/N
11. The area beneath the stairs in the ground floor are not converted into material store/ or store of junks : Y/N

12. Mockdrills are practiced at regular interval in the hospital. Y/N

13. Frequency of Mockdrills Practised in the hospital: Monthly/ bimonthly/ Quarterly

14. All categories of staffs are involved in the hospital including staffs of inhouse PPP units of the hospitals: Y/N

15. Present status of Fire Safety License : Applied/ joint inspection with Fire Dept. done /FSR received/ Progress of civil and electrical work according to FSR/ Compliance Report Submitted to Fire Dept.

16. If applied, AIN NO. & Date of Application:

15. If Fire Safety Certificate Received, then FSC No. & Validity period:

Checklist (to be filled up by PWD CIVIL):

Name of the Hospital:

Date and time of Inspection :

Name of the Building:

Floor:

A.CONSTRUCTION:

1. The construction of the existing building is carried out as per approved plan drawings conforming the relevant building rules of local Municipal Body : Y/N
2. The floor area exceeding 750 m sq. is suitably compartmented by separation walls up to ceiling level having two hours fire resisting capacity as per norms. Y/N
3. The interior finish of the building is made of low flame spread materials conforming is specifications. . Y/N
4. Provision of ventilation at the crown of the central core-duct of the building is provided. . Y/N
5. Arrangement is made for sealing all the vertical and horizontal ducts by the materials of adequate fire resisting capacity. Y/N
6. Roof as used as a refuge area in case of an emergency and it should be clear open to sky for all time. No permanent or temporary structure is allowed on the roof. . Y/N

B. OPEN SPACE AND APPROACH:

1. The open spaces surrounding the building conforms the relevant building rules and permit the accessibility and maneuverability of Fire Appliances with turning facility. Y/N
2. The approach road is sufficiently strong to withstand the load of Fire Engine sighting 45M.T. Y/N
3. The width and height of the access gate into the premises is not less than 4.5 mts. and 5.0 mts. respecting the abutting road. Y/N
4. Drive way should be free from any type of obstruction. No parking will be allowed on the drive way. Y/N
5. All the Passage way are kept clear for free access. Y/N

C. STAIRCASES:

1. The staircase of the building is enclosed type. Entire construction is made of bricks/R.C C. type having Fire Resisting capacity not less than 4 hours. Y/N
2. The staircase of the building is provided with permanent vents at the top and open able sashes at each floor level in the external walls of the building. Y/N
3. The width of the staircase is constructed as marked in the plan. Corridors and the exit doors conforms the relevant Building Rules to up to date amendment. Y/N
4. All staircases is extended up to terrace of the building and is negotiated to each floor. Y/N
5. Staircases and ramps is constructed maintaining the travel distance and dead end as per NBC Part -IV,2016 as marked shown in the plan of the hospital building for easy evacuation. Y/N
6. Fire and smoke doors at the entrances of all the staircase enclosures as marked in the plan at each floor level are provided. The F.C.D. is at least one hour Fire resisting wire glass window fitted with self-closing type open able in the direction of escape. Y/N

D. FIRE FIGHTING WATER:

Underground water reservoir having water capacity of 1,50,000 ltrs. and over head water reservoir having capacity of 30,000ltrs exclusively for fire-fighting purpose with replenishing arrangements@ 1000 ltrs/min. preferably from two different sources of water supply is provided. The water reservoirs have overflow arrangement with the domestic water reservoir as well as to avoid stagnancy of water. The water reservoir is kept full at all time. ----- Available /Not available

E. HYDRANT SYSTEM:

1. The building shall be provided with Wet Riser of 150 mm. internal diameter pipe line with provision of landing valves at the staircase landings/half landings at the rate of one such riser for 1000 sq m of floor area. The system is so designed that kept charged with water all the time under pressure and capable to discharge 2850ltrs /min. at the ground level outlet and minimum 900ltrs/min. at the top most outlet. In both cases the running pressure is not less than 3.5 kgs/sq.cm. All other requirements conforms I.S. 3844- 1989. Available/ Not Available

2 Provision of standard Hose Reel Hose supplied from the overhead or underground reservoir through Booster Pump is made in all the floor of the building satisfy the code of I.S. 3544- 1989.

Available/ not Available

3. Yard Hydrant/Ring Main Hydrant with provision of adequate numbers hydrant is installed surrounding the building in accordance with relevant I.S. specifications. Proper replenishing arrangements is made to keep the overhead water reservoir full at all time. Available/ not Available

F. SPRINKLER INSTALLATION:

The automatic sprinkler installation is provided in all floor areas of the building as per I.S. 9972. Alarm Gong to be incorporated along with the sprinkler system and test line is provided. -Y/N

G. FIRE PUMP:

1. Provision of the Fire Pump is to be made to supply water at the rate-designed pressure and discharge into the Water based system, which is installed in the building. One such pump always be kept on stand-by preferably be of diesel driven type. Y/N
2. A Separate fire Pump shall preferably be made for the total Sprinkler Installation of the buildings. Provision of the Jockey Pump have to be made to keep the water based system under pressurized condition at all the time. All the pumps is incorporated with both manual and auto starting facilities. The suction of pumps is preferably of positive type or in case of negative suction the system be wet riser cum down comer with suitable terrace pump with overhead tank.

Available/ Not Available

1. Any Recommendation from PWD(civil):- (extra sheet may be attached):

2. Any Recommendation from PWD(elec):- (extra sheet may be attached):

3. Any Recommendation from Hospital Authority:- (extra sheet may be attached):

4. Any recommendation of Nodal Officer , WBF& ES: (extra sheet may be attached):

5. Signature of Nodal Officer (Hospital) with designation : _____

6. Signature of Nodal Officer PWD(Electrical) with designation: _____

7. Signature of Nodal Officer PWD(CIVIL) with designation: _____

8. Signature of Nodal Officer PWD(WBF&ES) with designation: _____